



Total Quality. Assured.

545 E Algonquin Road, Suite H
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667
intertek.com

Published: July 22, 2020
Revised:

Public Notice ID: 2020-17
Page 1 of 2

Safety Concern with Intertek Certified Product / Souci de sécurité avec le produit certifié Intertek

Lennox Ductless Single-Zone and Multi-Zone heat pumps

Notification Type:	Safety / Sécurité
Certification Type:	ETL Listed - US and Canada

Notification

Intertek notifies consumers, retailers and distributors of a potential safety concern involving the Intertek Certified products identified below. / Intertek informe les consommateurs, les détaillants et les distributeurs d'une préoccupation potentielle en matière de sécurité impliquant les produits certifiés Intertek identifiés ci-dessous.

Company Identification

GD Midea Air Conditioning Equipment Co. Ltd.

Product Identification

The recalled products are Lennox Ductless Single-Zone and Multi-Zone heat pumps model # MPA018S4M-1P, MPA048S4S-1P and MPA048S4M-1P, and have a serial numbers beginning with 6915XXXXXX or 6916XXXXXX. Recall number: 20-083 see link <https://www.cpsc.gov/Recalls/2020/Lennox-Industries-Recalls-Ductless-Heat-Pumps-Due-to-Fire-Hazard>

Hazard Involved

Internal electrical components can fail, allowing the units to overheat, posing a fire hazard

What To Do

Use of these products should be immediately discontinued and return to the point of purchase. Distributors and retailers should discontinue sales and return inventories to their suppliers. / L'utilisation de ces produits doit être immédiatement abandonnée et retourner au point d'achat. Les distributeurs et les détaillants doivent cesser les ventes et retourner les inventaires à leurs fournisseurs.



Total Quality. Assured.

Published: July 22, 2020
Revised:

Photos and Images

545 E Algonquin Road, Suite H
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667
intertek.com

Public Notice ID: 2020-17
Page 2 of 2

